

东莞市2017年第三季度七月份国控企业污染源（重金属废水）监督性监测结果

序号	行政区	企业名称	监测点名称	执行标准名称	监测日期	监测项目名称	污染物浓度	标准限值	单位	是否达标	超标倍数	备注
1	东莞市	东莞长安华南电子厂	镍预处理排放口	电镀水污染物排放标准	2017/7/17	总汞	<0.00004	0.005	mg/L	是		
						总镉	<0.005	0.01	mg/L	是		
						总铬	<0.03	0.5	mg/L	是		
						六价铬	<0.004	0.1	mg/L	是		
						总铅	<0.07	0.1	mg/L	是		
						总银	<0.02	0.1	mg/L	是		
						总镍	<0.02	0.5	mg/L	是		
						总汞	<0.00004	0.005	mg/L	是		
						总镉	<0.005	0.01	mg/L	是		
						总铬	<0.03	0.5	mg/L	是		
						六价铬	<0.004	0.1	mg/L	是		
						总砷	<0.0003		mg/L			
						总铅	<0.07	0.1	mg/L	是		
			总镍			<0.02	0.5	mg/L	是			
			总铜			<0.006	0.5	mg/L	是			
			总锌			<0.004	1	mg/L	是			
			pH值			7.73	6-9	无量纲	是			
			氨氮			<0.025	15	mg/L	是			
			氟化物			3.92	10	mg/L	是			
			化学需氧量			<10	80	mg/L	是			
			石油类			0.05	2.0	mg/L	是			
			悬浮物			8	30	mg/L	是			
			总氮			3.75	20	mg/L	是			
			总磷			0.03	1.0	mg/L	是			
			总铝			<0.07	2.0	mg/L	是			
			总氰化物			<0.001	0.2	mg/L	是			
总铁	<0.02	2.0	mg/L	是								
总银	<0.02	0.1	mg/L	是								
2	东莞市	东莞三兴五金制品有限公司	铬预处理排放口	电镀水污染物排放标准	2017/7/10	总汞	<0.00004	0.005	mg/L	是		废水汇入东莞市合丰投资有限公司
						总镉	<0.005	0.01	mg/L	是		
						总铬	<0.03	0.5	mg/L	是		
						六价铬	0.008	0.1	mg/L	是		
						总铅	<0.07	0.1	mg/L	是		
			总银			<0.02	0.1	mg/L	是			
			总镍			<0.02	0.5	mg/L	是			
			总汞			<0.00004	0.005	mg/L	是			
			总镉			<0.005	0.01	mg/L	是			
			总铬			<0.03	0.5	mg/L	是			
			六价铬			0.005	0.1	mg/L	是			
			总铅			<0.07	0.1	mg/L	是			
			总银			<0.02	0.1	mg/L	是			
			总镍			0.18	0.5	mg/L	是			
			总汞			<0.00004	0.005	mg/L	是			
			总镉			<0.005	0.01	mg/L	是			
			总铬			<0.03	0.5	mg/L	是			
			六价铬			0.005	0.1	mg/L	是			
			总砷			<0.0003		mg/L				
			总铅			<0.07	0.1	mg/L	是			

3	东莞市	东莞市佳钦五金塑胶有限公司	总排放口	电镀水污染物排放标准	2017/7/10	总镍	0.18	0.5	mg/L	是	(路东片区)
						总铜	0.19	1	mg/L	是	
						总锌	0.322	2	mg/L	是	
	pH值	7.89	6-9	无量纲	是						
	氨氮	3.01	15	mg/L	是						
	氟化物	0.89	10	mg/L	是						
	化学需氧量	<10	80	mg/L	是						
	石油类	0.12	2.0	mg/L	是						
	悬浮物	6	30	mg/L	是						
	总氮	17.4	20	mg/L	是						
	总磷	0.07	1.0	mg/L	是						
	总铝	<0.07	2.0	mg/L	是						
	总氰化物	<0.001	0.2	mg/L	是						
	总铁	0.10	2.0	mg/L	是						
	总银	<0.02	0.1	mg/L	是						
	镍预处理排放口		总汞	<0.00004	0.005	mg/L	是	废水汇入东莞市合丰投资有限公司(路东片区)			
			总镉	<0.005	0.01	mg/L	是				
			总铬	<0.03	0.5	mg/L	是				
			六价铬	0.005	0.1	mg/L	是				
			总铅	<0.07	0.1	mg/L	是				
			总银	<0.02	0.1	mg/L	是				
			总镍	0.18	0.5	mg/L	是				
			总汞	<0.00004	0.005	mg/L	是				
			总镉	<0.005	0.01	mg/L	是				
			总铬	<0.03	0.5	mg/L	是				
			六价铬	0.005	0.1	mg/L	是				
			总砷	<0.0003		mg/L					
			总铅	<0.07	0.1	mg/L	是				
			总镍	0.18	0.5	mg/L	是				
			总铜	0.19	1	mg/L	是				
			总锌	0.322	2	mg/L	是				
			pH值	7.89	6-9	无量纲	是				
			氨氮	3.01	15	mg/L	是				
			氟化物	0.89	10	mg/L	是				
			化学需氧量	<10	80	mg/L	是				
			石油类	0.12	2.0	mg/L	是				
			悬浮物	6	30	mg/L	是				
			总氮	17.4	20	mg/L	是				
			总磷	0.07	1.0	mg/L	是				
			总铝	<0.07	2.0	mg/L	是				
			总氰化物	<0.001	0.2	mg/L	是				
			总铁	0.10	2.0	mg/L	是				
			总银	<0.02	0.1	mg/L	是				
			总汞	<0.00004	0.005	mg/L	是				
			总镉	<0.005	0.01	mg/L	是				
			总铬	<0.03	0.5	mg/L	是				
			六价铬	0.008	0.1	mg/L	是				
			总铅	<0.07	0.1	mg/L	是				
			总银	<0.02	0.1	mg/L	是				
			总镍	0.17	0.5	mg/L	是				
			总汞	<0.00004	0.005	mg/L	是				
			总镉	<0.005	0.01	mg/L	是				
			总铬	<0.03	0.5	mg/L	是				
			六价铬	0.008	0.1	mg/L	是				

4	东莞市	东莞市乾发电镀有限公司(原东莞市虎门润威五金塑胶制品有限公司)	镍预处理排放口	电镀水污染物排放标准	2017/7/10	总铅	<0.07	0.1	mg/L	是	
			总排放口			总银	<0.02	0.1	mg/L	是	
5	东莞市	东莞长安品质电子制造厂	总排放口	地表水环境质量标准	2017/7/10	总镍	0.17	0.5	mg/L	是	
						总汞	<0.00004	0.005	mg/L	是	
						总镉	<0.005	0.01	mg/L	是	
						总铬	<0.03	0.5	mg/L	是	
						六价铬	0.005	0.1	mg/L	是	
						总铅	<0.07	0.1	mg/L	是	
						总银	<0.02	0.1	mg/L	是	
						总镍	0.18	0.5	mg/L	是	
						总汞	<0.00004	0.005	mg/L	是	
						总镉	<0.005	0.01	mg/L	是	
			总铬	<0.03		0.5	mg/L	是			
			六价铬	0.005		0.1	mg/L	是			
			总砷	<0.0003			mg/L				
			总铅	<0.07		0.1	mg/L	是			
			总镍	0.18		0.5	mg/L	是			
			总铜	0.19		1	mg/L	是			
			总锌	0.322		2	mg/L	是			
			pH值	7.89		6-9	无量纲	是			
			氨氮	3.01		15	mg/L	是			
			氟化物	0.89		10	mg/L	是			
化学需氧量	<10	80	mg/L	是							
石油类	0.12	2.0	mg/L	是							
悬浮物	6	30	mg/L	是							
总氮	17.4	20	mg/L	是							
总磷	0.07	1.0	mg/L	是							
总铝	<0.07	2.0	mg/L	是							
总氰化物	<0.001	0.2	mg/L	是							
总铁	0.10	2.0	mg/L	是							
总银	<0.02	0.1	mg/L	是							
六价铬	0.007	0.05	mg/L	是							
砷	<0.0003	0.1	mg/L	是							
汞	<0.00004	0.001	mg/L	是							
镉	<0.005	0.005	mg/L	是							
铅	<0.01	0.05	mg/L	是							
氨氮	0.125	1.5	mg/L	是							
氟化物	0.49	1.5	mg/L	是							
化学需氧量	<10	30	mg/L	是							
石油类	0.12	0.5	mg/L	是							
总磷	0.05	0.3	mg/L	是							
总氮	2.23	1.5	mg/L	否	0.5						
总镍	<0.02	0.5	mg/L	是							
总铬	<0.03	0.5	mg/L	是							
pH值	7.43	6-9	无量纲	是							
悬浮物	9	30	mg/L	是							
总铝	<0.07	2.0	mg/L	是							
总氰化物	<0.001	0.2	mg/L	是							
总铁	<0.02	2.0	mg/L	是							
总银	<0.02	0.1	mg/L	是							
总锌	<0.004	1	mg/L	是							

废水汇入东莞市合丰环保投资有限公司(路东片区)

				广东省地方标准《水污染物排放限值》		总铜	<0.006	0.5	mg/L	是	
				银预处理排放口		地表水环境质量标准	六价铬	0.006	0.05	mg/L	
				电镀污染物排放标准		汞	<0.00004	0.001	mg/L	是	
						镉	<0.005	0.005	mg/L	是	
						铅	<0.01	0.05	mg/L	是	
						总镍	<0.02	0.1	mg/L	是	
						总银	<0.02	0.1	mg/L	是	
						总铬	<0.03	0.5	mg/L	是	
						总汞	<0.00004	0.005	mg/L	是	
						总镉	<0.005	0.01	mg/L	是	
						总铬	<0.03	0.5	mg/L	是	
						六价铬	0.007	0.1	mg/L	是	
						总砷	<0.0003		mg/L		
						总铅	<0.07	0.1	mg/L	是	
						总镍	<0.02	0.5	mg/L	是	
						总铜	0.01	1	mg/L	是	
						总锌	0.012	2	mg/L	是	
						pH值	6.86	6-9	无量纲	是	
						氨氮	0.352	15	mg/L	是	
						氟化物	0.25	10	mg/L	是	
						化学需氧量	<10	80	mg/L	是	
						石油类	0.10	2.0	mg/L	是	
						悬浮物	5	30	mg/L	是	
						总氮	3.72	20	mg/L	是	
						总磷	0.02	1.0	mg/L	是	
						总铝	0.10	2.0	mg/L	是	
						总氰化物	<0.001	0.2	mg/L	是	
						总铁	0.71	2.0	mg/L	是	
						总银	<0.02	0.1	mg/L	是	
						总汞	<0.00004	0.005	mg/L	是	
						总镉	<0.005	0.01	mg/L	是	
						总铬	<0.03	0.5	mg/L	是	
						六价铬	0.01	0.1	mg/L	是	
						总铅	<0.07	0.1	mg/L	是	
						总银	<0.02	0.1	mg/L	是	
						总镍	<0.02	0.5	mg/L	是	
						总汞	<0.00004	0.005	mg/L	是	
						总镉	<0.005	0.01	mg/L	是	
						总铬	<0.03	0.5	mg/L	是	
						六价铬	0.01	0.1	mg/L	是	
						总铅	<0.07	0.1	mg/L	是	
						总银	<0.02	0.1	mg/L	是	
						总镍	0.1	0.5	mg/L	是	
						总汞	<0.00004	0.005	mg/L	是	
						总镉	<0.005	0.01	mg/L	是	
						总铬	<0.03	0.5	mg/L	是	
						六价铬	0.01	0.1	mg/L	是	
						总铅	<0.07	0.1	mg/L	是	
						总银	<0.02	0.1	mg/L	是	
						总镍	0.1	0.5	mg/L	是	
						总汞	<0.00004	0.005	mg/L	是	
						总镉	<0.005	0.01	mg/L	是	
						总铬	<0.03	0.5	mg/L	是	
						六价铬	0.01	0.1	mg/L	是	
						总铅	<0.07	0.1	mg/L	是	
						总银	<0.02	0.1	mg/L	是	

废水汇入东莞市成工业污水处理中心

6

东莞市

东莞长安生兴五金电镀厂(利华)

总排放口

铬预处理排放口

混排预处理排放口

镍预处理排放口

电镀水污染物排放标准

2017/7/10

7	东莞市	东莞达成金属制品有限公司	总排放口	电镀水污染物排放标准	2017/7/17	总镍	<0.02	0.5	mg/L	是
						总砷	<0.0003		mg/L	
						总铅	<0.07	0.1	mg/L	是
						总镍	0.1	0.5	mg/L	是
						总铜	<0.006	0.5	mg/L	是
						总锌	<0.004	1	mg/L	是
						总汞	<0.00004	0.005	mg/L	是
						总镉	<0.005	0.01	mg/L	是
						总铬	<0.03	0.5	mg/L	是
						六价铬	0.021	0.1	mg/L	是
						pH值	7.31	6-9	无量纲	是
						氨氮	0.296	15	mg/L	是
						氟化物	1.4	10	mg/L	是
						化学需氧量	28	80	mg/L	是
						石油类	0.12	2.0	mg/L	是
			悬浮物			6	30	mg/L	是	
			总氮			4.23	20	mg/L	是	
			总磷			0.02	1.0	mg/L	是	
			总氰化物			<0.001	0.2	mg/L	是	
			总铁			<0.02	2.0	mg/L	是	
			总银			<0.02	0.1	mg/L	是	
			总汞			<0.00004	0.005	mg/L	是	
			总镉			<0.005	0.01	mg/L	是	
			总铬			<0.03	0.5	mg/L	是	
			六价铬			<0.004	0.1	mg/L	是	
			总铅			<0.07	0.1	mg/L	是	
			总银			<0.02	0.1	mg/L	是	
			总镍			<0.02	0.5	mg/L	是	
			总汞			<0.00004	0.005	mg/L	是	
			总镉			<0.005	0.01	mg/L	是	
			总铬			<0.03	0.5	mg/L	是	
			六价铬			<0.004	0.1	mg/L	是	
			总铅			<0.07	0.1	mg/L	是	
总银	<0.02	0.1	mg/L	是						
总镍	<0.02	0.5	mg/L	是						
总汞	<0.00004	0.005	mg/L	是						
总镉	<0.005	0.01	mg/L	是						
总铬	<0.03	0.5	mg/L	是						
六价铬	<0.004	0.1	mg/L	是						
总铅	<0.07	0.1	mg/L	是						
总银	<0.02	0.1	mg/L	是						
总镍	<0.02	0.5	mg/L	是						
总汞	<0.00004	0.005	mg/L	是						
总镉	<0.005	0.01	mg/L	是						
总铬	<0.03	0.5	mg/L	是						
六价铬	<0.004	0.1	mg/L	是						
总砷	0.0005		mg/L							
总铅	<0.07	0.1	mg/L	是						
总镍	<0.02	0.5	mg/L	是						
总铜	<0.006	0.5	mg/L	是						
总锌	<0.004	1	mg/L	是						
pH值	7.07	6-9	无量纲	是						
氨氮	0.295	15	mg/L	是						
氟化物	0.20	10	mg/L	是						
8	东莞市	东莞东旭金属表面处理有限公司	镍预处理排放口	电镀水污染物排放标准	2017/7/12	总汞	<0.00004	0.005	mg/L	是
						总镉	<0.005	0.01	mg/L	是
						总铬	<0.03	0.5	mg/L	是
						六价铬	<0.004	0.1	mg/L	是
						总铅	<0.07	0.1	mg/L	是
						总银	<0.02	0.1	mg/L	是
						总镍	<0.02	0.5	mg/L	是
			总汞			<0.00004	0.005	mg/L	是	
			总镉			<0.005	0.01	mg/L	是	
			总铬			<0.03	0.5	mg/L	是	
			六价铬			<0.004	0.1	mg/L	是	
			总砷			0.0005		mg/L		
			总铅			<0.07	0.1	mg/L	是	
			总镍			<0.02	0.5	mg/L	是	
			总铜			<0.006	0.5	mg/L	是	
总锌	<0.004	1	mg/L	是						
pH值	7.07	6-9	无量纲	是						
氨氮	0.295	15	mg/L	是						
氟化物	0.20	10	mg/L	是						
			总排放口			总镍	<0.02	0.5	mg/L	是
						总汞	<0.00004	0.005	mg/L	是

9	东莞市	东莞虎门新海电镀有限公司	电镀水污染物排放标准	2017/7/10	化学需氧量	<10	80	mg/L	是	
					石油类	<0.04	2.0	mg/L	是	
					悬浮物	5	30	mg/L	是	
					总氮	1.14	20	mg/L	是	
					总磷	0.01	1.0	mg/L	是	
					总铝	<0.07	2.0	mg/L	是	
					总氰化物	<0.001	0.2	mg/L	是	
					总铁	<0.02	2.0	mg/L	是	
					总银	<0.02	0.1	mg/L	是	
					总汞	<0.00004	0.005	mg/L	是	
					总镉	<0.005	0.01	mg/L	是	
					总铬	<0.03	0.5	mg/L	是	
					六价铬	0.008	0.1	mg/L	是	
					总铅	<0.07	0.1	mg/L	是	
					总银	<0.02	0.1	mg/L	是	
					总镍	0.17	0.5	mg/L	是	
					总汞	<0.00004	0.005	mg/L	是	
					总镉	<0.005	0.01	mg/L	是	
					总铬	<0.03	0.5	mg/L	是	
					六价铬	0.005	0.1	mg/L	是	
					总铅	<0.07	0.1	mg/L	是	
					总银	<0.02	0.1	mg/L	是	
					总镍	0.18	0.5	mg/L	是	
					总汞	<0.00004	0.005	mg/L	是	
					总镉	<0.005	0.01	mg/L	是	
					总铬	<0.03	0.5	mg/L	是	
					六价铬	0.005	0.1	mg/L	是	
					总砷	<0.0003		mg/L		
					总铅	<0.07	0.1	mg/L	是	
					总镍	0.18	0.5	mg/L	是	
					总铜	0.19	1	mg/L	是	
					总锌	0.322	2	mg/L	是	
					pH值	7.89	6-9	无量纲	是	
氨氮	3.01	15	mg/L	是						
氟化物	0.89	10	mg/L	是						
化学需氧量	<10	80	mg/L	是						
石油类	0.12	2.0	mg/L	是						
悬浮物	6	30	mg/L	是						
总氮	17.4	20	mg/L	是						
总磷	0.07	1.0	mg/L	是						
总铝	<0.07	2.0	mg/L	是						
总氰化物	<0.001	0.2	mg/L	是						
总铁	0.10	2.0	mg/L	是						
总银	<0.02	0.1	mg/L	是						
总汞	<0.00004	0.005	mg/L	是						
总镉	<0.005	0.01	mg/L	是						
总铬	<0.03	0.5	mg/L	是						
六价铬	0.006	0.1	mg/L	是						
总砷	0.00033		mg/L							
总铅	<0.07	0.1	mg/L	是						
总镍	<0.02	0.5	mg/L	是						

废水汇入东莞市合丰投资有限公司（路东片区）

废水汇入

10	东莞市	东莞佳男五金电镀有限公司	总排放口	电镀水污染物排放标准	2017/7/10	总铜	0.062	1	mg/L	是	东莞市合丰环保投资有限公司(南栅片区)						
						总锌	<0.004	2	mg/L	是							
						pH值	7.35	6-9	无量纲	是							
						氨氮	0.9	15	mg/L	是							
						氟化物	0.08	10	mg/L	是							
						化学需氧量	<10	80	mg/L	是							
						石油类	0.06	2.0	mg/L	是							
						悬浮物	4	30	mg/L	是							
						总氮	4.99	20	mg/L	是							
						总磷	0.07	1.0	mg/L	是							
						总铝	<0.07	2.0	mg/L	是							
						总氰化物	<0.001	0.2	mg/L	是							
						总铁	<0.02	2.0	mg/L	是							
						总银	<0.02	0.1	mg/L	是							
11	东莞市	东莞嘉丰机电设备有限公司	铬预处理排放口	电镀水污染物排放标准	2017/7/13	总汞	<0.00004	0.005	mg/L	是							
						总镉	<0.005	0.01	mg/L	是							
						总铬	0.15	0.5	mg/L	是							
						六价铬	0.009	0.1	mg/L	是							
						总铅	<0.07	0.1	mg/L	是							
						总银	<0.02	0.1	mg/L	是							
						总镍	<0.02	0.5	mg/L	是							
						总汞	<0.00004	0.005	mg/L	是							
						总镉	<0.005	0.01	mg/L	是							
						总铬	<0.03	0.5	mg/L	是							
						六价铬	<0.004	0.1	mg/L	是							
						总铅	<0.07	0.1	mg/L	是							
						总镍	<0.02	0.5	mg/L	是							
						总铜	0.067	0.5	mg/L	是							
			总锌			0.074	1	mg/L	是								
			pH值			7.35	6-9	无量纲	是								
			氨氮			0.096	15	mg/L	是								
			氟化物			0.29	10	mg/L	是								
			化学需氧量			<10	80	mg/L	是								
			石油类			<0.04	2.0	mg/L	是								
			悬浮物			5	30	mg/L	是								
			总氮			4.13	20	mg/L	是								
			总磷			0.02	1.0	mg/L	是								
			总氰化物			<0.001	0.2	mg/L	是								
			总铁			<0.02	2.0	mg/L	是								
			总银			<0.02	0.1	mg/L	是								
								镍预处理排放口				总汞	<0.00004	0.005	mg/L	是	
												总镉	<0.005	0.01	mg/L	是	
总铬	<0.03	0.5		mg/L	是												
六价铬	<0.004	0.1		mg/L	是												
总铅	<0.07	0.1		mg/L	是												
总银	<0.02	0.1		mg/L	是												
总镍	<0.02	0.5		mg/L	是												
总汞	<0.00004	0.005		mg/L	是												

12	东莞市	东莞建通电子五金有限公司	总排放口	电镀水污染物排放标准	2017/7/10	总镉	<0.005	0.01	mg/L	是	
						总铬	<0.03	0.5	mg/L	是	
						六价铬	<0.004	0.1	mg/L	是	
						总砷	<0.0003		mg/L		
						总铅	<0.07	0.1	mg/L	是	
						总镍	0.43	0.5	mg/L	是	
						总铜	0.037	0.5	mg/L	是	
						总锌	0.029	1	mg/L	是	
						pH值	7.42	6-9	无量纲	是	
						氨氮	0.254	15	mg/L	是	
						氟化物	0.11	10	mg/L	是	
						化学需氧量	57	80	mg/L	是	
						石油类	0.10	2.0	mg/L	是	
						悬浮物	7	30	mg/L	是	
						总氮	5.10	20	mg/L	是	
						总磷	0.22	1.0	mg/L	是	
						总铝	<0.07	2.0	mg/L	是	
						总氰化物	<0.001	0.2	mg/L	是	
						总铁	0.26	2.0	mg/L	是	
						总银	<0.02	0.1	mg/L	是	
13	东莞市	东莞茂林电子有限公司	镍预处理排放口	电镀水污染物排放标准	2017/7/10	总汞	<0.00004	0.005	mg/L	是	
						总镉	<0.005	0.01	mg/L	是	
						总铬	<0.03	0.5	mg/L	是	
						六价铬	0.009	0.1	mg/L	是	
						总铅	<0.07	0.1	mg/L	是	
						总银	<0.02	0.1	mg/L	是	
						总镍	<0.02	0.5	mg/L	是	
			总排放口	广东省地方标准《水污染物排放限值》		总汞	<0.00004	0.05	mg/L	是	
					总镉	<0.005	0.1	mg/L	是		
						总铬	<0.03	1.5	mg/L	是	
						六价铬	0.01	0.5	mg/L	是	
						总砷	0.0011	0.5	mg/L	是	
						总铅	<0.07	1	mg/L	是	
						总镍	<0.02	1	mg/L	是	
						总铜	<0.006	1	mg/L	是	
						总锌	<0.004	2	mg/L	是	
						pH值	7.15	6-9	无量纲	是	
						氨氮	0.2	10	mg/L	是	
						氟化物	2.87	10	mg/L	是	
						化学需氧量	21	90	mg/L	是	
						石油类	0.11	5	mg/L	是	
						悬浮物	13	60	mg/L	是	
						总氮	7.64	-	mg/L		
						总磷	0.48	0.5	mg/L	是	
						总铝	<0.07	-	mg/L		
						总氰化物	<0.001	0.05	mg/L	是	
						总铁	<0.02	-	mg/L		
						总银	<0.02	0.5	mg/L	是	

废水汇入东莞市丰环投资有限公司（南栅片区）

14	东莞市	东莞润丰金属塑胶有限公司	铬预处理排放口	电镀水污染物排放标准	总汞	<0.00004	0.005	mg/L	是	
			镍预处理排放口		总镉	<0.005	0.01	mg/L	是	
					总铬	<0.03	0.5	mg/L	是	
					六价铬	0.006	0.1	mg/L	是	
					总铅	<0.07	0.1	mg/L	是	
					总银	<0.02	0.1	mg/L	是	
				总镍	<0.02	0.5	mg/L	是		
			排放口	电镀水污染物排放标准	总汞	<0.00004	0.005	mg/L	是	
					总镉	<0.005	0.01	mg/L	是	
					总铬	<0.03	0.5	mg/L	是	
					六价铬	0.019	0.1	mg/L	是	
					总铅	<0.07	0.1	mg/L	是	
					总银	<0.02	0.1	mg/L	是	
					总镍	<0.02	0.5	mg/L	是	
					总砷	0.00055		mg/L		
					总铅	<0.07	0.1	mg/L	是	
					总镍	<0.02	0.5	mg/L	是	
					总铜	<0.006	0.5	mg/L	是	
					总锌	<0.004	1	mg/L	是	
					总汞	<0.00004	0.005	mg/L	是	
					总镉	<0.005	0.01	mg/L	是	
					总铬	<0.03	0.5	mg/L	是	
					六价铬	<0.004	0.1	mg/L	是	
					pH值	7.87	6-9	无量纲	是	
					氨氮	0.125	15	mg/L	是	
					氟化物	1.37	10	mg/L	是	
					化学需氧量	18	80	mg/L	是	
					石油类	0.04	2.0	mg/L	是	
					悬浮物	9	30	mg/L	是	
					总氮	2.62	20	mg/L	是	
总磷	<0.01	1.0			mg/L	是				
总氰化物	<0.001	0.2	mg/L	是						
总铁	0.07	2.0	mg/L	是						
总银	<0.02	0.1	mg/L	是						
15	东莞市	东莞上和五金电镀有限公司(原东莞东霖五金电镀有限公司)	铬预处理排放口	电镀水污染物排放标准	总汞	<0.00004	0.005	mg/L	是	
			镍预处理排放口		总镉	<0.005	0.01	mg/L	是	
					总铬	<0.03	0.5	mg/L	是	
					六价铬	0.008	0.1	mg/L	是	
					总铅	<0.07	0.1	mg/L	是	
					总银	<0.02	0.1	mg/L	是	
				总镍	0.17	0.5	mg/L	是		
			排放口	电镀水污染物排放标准	总汞	<0.00004	0.005	mg/L	是	
					总镉	<0.005	0.01	mg/L	是	
					总铬	<0.03	0.5	mg/L	是	
					六价铬	0.005	0.1	mg/L	是	
					总铅	<0.07	0.1	mg/L	是	
					总银	<0.02	0.1	mg/L	是	
					总镍	0.18	0.5	mg/L	是	
					总汞	<0.00004	0.005	mg/L	是	
总镉	<0.005	0.01			mg/L	是				
总铬	<0.03	0.5	mg/L	是						
六价铬	0.005	0.1	mg/L	是						
总砷	<0.0003		mg/L							
总铅	<0.07	0.1	mg/L	是						

废水汇入东莞市合丰投资有限公司

16	东莞市	东莞市长安新民茂程电镀厂	电镀水污染物排放标准	2017/7/10	废水汇入东莞市民成工业污水处理中心	(路东片区)	总排放口	总镍	0.18	0.5	mg/L	是	
							总铜	0.19	1	mg/L	是		
							总锌	0.322	2	mg/L	是		
							pH值	7.89	6-9	无量纲	是		
							氨氮	3.01	15	mg/L	是		
							氟化物	0.89	10	mg/L	是		
							化学需氧量	<10	80	mg/L	是		
							石油类	0.12	2.0	mg/L	是		
							悬浮物	6	30	mg/L	是		
							总氮	17.4	20	mg/L	是		
							总磷	0.07	1.0	mg/L	是		
							总铝	<0.07	2.0	mg/L	是		
							总氰化物	<0.001	0.2	mg/L	是		
							总铁	0.10	2.0	mg/L	是		
							总银	<0.02	0.1	mg/L	是		
							镍预处理排放口	总汞	<0.00004	0.005	mg/L	是	
总镉	<0.005	0.01	mg/L	是									
总铬	<0.03	0.5	mg/L	是									
六价铬	0.01	0.1	mg/L	是									
总铅	<0.07	0.1	mg/L	是									
总银	<0.02	0.1	mg/L	是									
总镍	<0.02	0.5	mg/L	是									
总汞	<0.00004	0.005	mg/L	是									
总镉	<0.005	0.01	mg/L	是									
总铬	<0.03	0.5	mg/L	是									
六价铬	0.007	0.1	mg/L	是									
总砷	<0.0003		mg/L										
总铅	<0.07	0.1	mg/L	是									
总镍	<0.02	0.5	mg/L	是									
总铜	0.01	1	mg/L	是									
总锌	0.012	2	mg/L	是									
pH值	6.86	6-9	无量纲	是									
氨氮	0.352	15	mg/L	是									
氟化物	0.25	10	mg/L	是									
化学需氧量	<10	80	mg/L	是									
石油类	0.10	2.0	mg/L	是									
悬浮物	5	30	mg/L	是									
总氮	3.72	20	mg/L	是									
总磷	0.02	1.0	mg/L	是									
总铝	0.10	2.0	mg/L	是									
总氰化物	<0.001	0.2	mg/L	是									
总铁	0.71	2.0	mg/L	是									
总银	<0.02	0.1	mg/L	是									
总汞	<0.00004	0.005	mg/L	是									
总镉	<0.005	0.01	mg/L	是									
总铬	<0.03	0.5	mg/L	是									
六价铬	0.01	0.1	mg/L	是									
总铅	<0.07	0.1	mg/L	是									
总银	<0.02	0.1	mg/L	是									
总镍	<0.02	0.5	mg/L	是									
总汞	<0.00004	0.005	mg/L	是									
总镉	<0.005	0.01	mg/L	是									
总铬	<0.03	0.5	mg/L	是									
六价铬	0.01	0.1	mg/L	是									
混排预处理排放口													

17	东莞市	东莞市明辉五金电镀有限公司	铬预处理排放口	电镀水污染物排放标准	2017/7/18	总铅	<0.07	0.1	mg/L	是	
						总银	<0.02	0.1	mg/L	是	
						总镍	0.1	0.5	mg/L	是	
						总汞	<0.00004	0.005	mg/L	是	
						总镉	<0.005	0.01	mg/L	是	
						总铬	<0.03	0.5	mg/L	是	
						六价铬	0.005	0.1	mg/L	是	
						总铅	<0.07	0.1	mg/L	是	
						总银	<0.02	0.1	mg/L	是	
						总镍	<0.02	0.5	mg/L	是	
						总汞	<0.00004	0.005	mg/L	是	
						总镉	<0.005	0.01	mg/L	是	
			总铬			<0.03	0.5	mg/L	是		
			六价铬			0.005	0.1	mg/L	是		
			总铅			<0.07	0.1	mg/L	是		
			总银			<0.02	0.1	mg/L	是		
			总镍			<0.02	0.5	mg/L	是		
			总汞			<0.00004	0.005	mg/L	是		
			总镉			<0.005	0.01	mg/L	是		
			总铬			<0.03	0.5	mg/L	是		
			六价铬			0.006	0.1	mg/L	是		
			总铅			<0.07	0.1	mg/L	是		
			总银			<0.02	0.1	mg/L	是		
			总镍			0.2	0.5	mg/L	是		
			总汞			<0.00004	0.005	mg/L	是		
			总镉			<0.005	0.01	mg/L	是		
			总铬			<0.03	0.5	mg/L	是		
			六价铬			<0.004	0.1	mg/L	是		
			总砷			<0.0003		mg/L			
			总铅			<0.07	0.1	mg/L	是		
			总镍			<0.02	0.5	mg/L	是		
			总铜			<0.006	0.5	mg/L	是		
			总锌			<0.004	1	mg/L	是		
			pH值			7.67	6-9	无量纲	是		
			氨氮			0.62	15	mg/L	是		
			氟化物			0.45	10	mg/L	是		
			化学需氧量			11	80	mg/L	是		
			石油类			0.17	2.0	mg/L	是		
			悬浮物			7	30	mg/L	是		
			总氮			1.36	20	mg/L	是		
			总磷			0.03	1.0	mg/L	是		
			总铝			<0.07	2.0	mg/L	是		
			总氰化物			<0.001	0.2	mg/L	是		
			总铁			<0.02	2.0	mg/L	是		
总银	<0.02	0.1	mg/L	是							
总砷	<0.0003		mg/L								
总铅	<0.07	0.1	mg/L	是							
总镍	0.18	0.5	mg/L	是							
总铜	0.19	1	mg/L	是							
总锌	0.322	2	mg/L	是							
总汞	<0.00004	0.005	mg/L	是							
总镉	<0.005	0.01	mg/L	是							
总铬	<0.03	0.5	mg/L	是							
六价铬	0.005	0.1	mg/L	是							

18	东莞市	东莞市艺海电镀有限公司	总排放口	电镀水污染物排放标准	2017/7/10	pH值	7.89	6-9	无量纲	是	
						氨氮	3.01	15	mg/L	是	
						氟化物	0.89	10	mg/L	是	
						化学需氧量	<10	80	mg/L	是	
						石油类	0.12	2.0	mg/L	是	
						悬浮物	6	30	mg/L	是	
						总氮	17.4	20	mg/L	是	
						总磷	0.07	1.0	mg/L	是	
						总铝	<0.07	2.0	mg/L	是	
						总氰化物	<0.001	0.2	mg/L	是	
						总铁	0.10	2.0	mg/L	是	
						总银	<0.02	0.1	mg/L	是	
						总汞	<0.00004	0.005	mg/L	是	
						总镉	<0.005	0.01	mg/L	是	
						总铬	<0.03	0.5	mg/L	是	
			铬预处理排放口			六价铬	0.008	0.1	mg/L	是	
						总铅	<0.07	0.1	mg/L	是	
						总银	<0.02	0.1	mg/L	是	
						总镍	0.17	0.5	mg/L	是	
						总汞	<0.00004	0.005	mg/L	是	
						总镉	<0.005	0.01	mg/L	是	
						总铬	<0.03	0.5	mg/L	是	
						六价铬	0.005	0.1	mg/L	是	
						总铅	<0.07	0.1	mg/L	是	
						总银	<0.02	0.1	mg/L	是	
						总镍	0.18	0.5	mg/L	是	
						总汞	<0.00004	0.005	mg/L	是	
						总镉	<0.005	0.01	mg/L	是	
						总铬	<0.03	0.5	mg/L	是	
						六价铬	0.005	0.1	mg/L	是	
						总铅	<0.07	0.1	mg/L	是	
						总银	<0.02	0.1	mg/L	是	
						总镍	<0.02	0.5	mg/L	是	
						总汞	<0.00004	0.005	mg/L	是	
						总镉	<0.005	0.01	mg/L	是	
						总铬	<0.03	0.5	mg/L	是	
						六价铬	<0.004	0.1	mg/L	是	
						总砷	<0.0003		mg/L		
						总铅	<0.07	0.1	mg/L	是	
						总镍	<0.02	0.5	mg/L	是	
						总铜	<0.006	0.5	mg/L	是	
						总锌	<0.004	1	mg/L	是	
						pH值	7.57	6-9	无量纲	是	
						氨氮	0.753	15	mg/L	是	
						氟化物	0.24	10	mg/L	是	
						化学需氧量	38	80	mg/L	是	
						石油类	<0.04	2.0	mg/L	是	
						悬浮物	6	30	mg/L	是	
						总氮	2.24	20	mg/L	是	
						总磷	<0.01	1.0	mg/L	是	
						总铝	0.32	2.0	mg/L	是	
						总氰化物	<0.001	0.2	mg/L	是	
						总铁	<0.02	2.0	mg/L	是	
						总银	<0.02	0.1	mg/L	是	
19	东莞市	乐依文半导体(东莞)有限公司	锡预处理排放口	电镀水污染物排放标准	2017/7/18						
			总排放口								

废水汇入东莞市合丰投资有限公司(路东片区)

20	东莞市	东莞市豪丰环保投资有限公司	电镀水污染物排放标准	2017/7/6 0:00	含铬废水预处理排放口	总铬	<0.03	0.5	mg/L	是
					含铬废水预处理排放口	六价铬	<0.004	0.1	mg/L	是
						总铅	<0.01	0.1	mg/L	是
						总镍	<0.05	0.5	mg/L	是
						总汞	<0.00004	0.005	mg/L	是
						总镉	<0.001	0.01	mg/L	是
						总银	<0.03	0.1	mg/L	是
					含镍废水预处理排放口	六价铬	<0.004	0.1	mg/L	是
						总铅	<0.01	0.1	mg/L	是
						总镍	<0.05	0.5	mg/L	是
						总银	<0.03	0.1	mg/L	是
						总汞	<0.00004	0.005	mg/L	是
						总镉	<0.001	0.01	mg/L	是
					总排放口	总铬	<0.03	0.5	mg/L	是
						总铜	<0.006	0.5	mg/L	是
						总锌	<0.004	1.0	mg/L	是
						总汞	<0.00004	0.005	mg/L	是
						总铅	<0.07	0.1	mg/L	是
						总镍	<0.02	0.5	mg/L	是
						总镉	<0.005	0.01	mg/L	是
						氨氮	0.11	15	mg/L	是
						化学需氧量	12	80	mg/L	是
						总氰化物	<0.001	0.2	mg/L	是
						总银	<0.03	0.1	mg/L	是
						总铬	<0.03	0.5	mg/L	是
						pH值	7.52	6~9	无量纲	是
						六价铬	<0.004	0.1	mg/L	是
						石油类	<0.04	2.0	mg/L	是
						悬浮物	<4	30.0	mg/L	是
						总磷	0.12	1.0	mg/L	是
						总铁	<0.02	2.0	mg/L	是
						总铝	<0.07	2.0	mg/L	是
						总氮	2.2	20.0	mg/L	是
氟化物	0.33	10	mg/L	是						
总砷	<0.0003		mg/L							
含铬废水预处理排放口	总汞	<0.00004	0.005	mg/L	是					
	总镉	<0.001	0.01	mg/L	是					
	总铬	<0.03	0.5	mg/L	是					
	六价铬	<0.004	0.1	mg/L	是					
	总铅	<0.01	0.1	mg/L	是					
	总镍	<0.05	0.5	mg/L	是					
含镍废水预处理排放口	总银	<0.03	0.1	mg/L	是					
	总汞	<0.00004	0.005	mg/L	是					
	总镉	<0.001	0.01	mg/L	是					
	总铬	<0.03	0.5	mg/L	是					
	六价铬	<0.004	0.1	mg/L	是					
	总铅	<0.01	0.1	mg/L	是					
混排废水预处理排放口	总镍	0.14	0.5	mg/L	是					
	总银	<0.03	0.1	mg/L	是					
	总汞	<0.00004	0.005	mg/L	是					
	总镉	0.01	0.01	mg/L	是					
	总铬	<0.03	0.5	mg/L	是					
	六价铬	<0.004	0.1	mg/L	是					
		总铅	<0.01	0.1	mg/L	是				

21	东莞市	东莞市齐美五金塑胶制造有限公司	总排放口	电镀水污染物排放标准	2017/7/11	总镍	0.22	0.5	mg/L	是	
						总银	<0.03	0.1	mg/L	是	
						总汞	<0.00004	0.005	mg/L	是	
						总镉	<0.001	0.01	mg/L	是	
						总铬	<0.03	0.5	mg/L	是	
						六价铬	<0.004	0.1	mg/L	是	
						总砷	<0.0003		mg/L		
						总铅	<0.01	0.1	mg/L	是	
						总镍	<0.05	0.5	mg/L	是	
						总铜	<0.05	0.5	mg/L	是	
						氨氮	0.033	15	mg/L	是	
						石油类	0.04	2.0	mg/L	是	
						悬浮物	<4	30	mg/L	是	
						总氮	2.58	20	mg/L	是	
						总磷	0.06	1.0	mg/L	是	
						化学需氧量	15	80	mg/L	是	
						总铁	<0.03	2.0	mg/L	是	
						总氰化物	<0.001	0.2	mg/L	是	
						pH值	7.80	6~9	无量纲	是	
						总铝	<0.07	2.0	mg/L	是	
						总银	<0.03	0.1	mg/L	是	
氟化物	0.11	10	mg/L	是							
总锌	<0.02	1	mg/L	是							
22	东莞辖镇	东莞柏狮精密电子有限公司	含银废水预处理排放口	电镀污染物排放标准	2017/7/6	总汞	<0.00004	0.005	mg/L	是	
			总镉			<0.001	0.01	mg/L	是		
			总铬			<0.03	0.5	mg/L	是		
			六价铬			<0.004	0.1	mg/L	是		
			总铅			<0.01	0.1	mg/L	是		
			总镍			<0.05	0.5	mg/L	是		
			总银			<0.03	0.1	mg/L	是		
			总锌			<0.004	1	mg/L	是		
			总汞			<0.00004	0.005	mg/L	是		
			总镉			<0.005	0.01	mg/L	是		
			总铬			<0.03	0.5	mg/L	是		
			六价铬			<0.004	0.1	mg/L	是		
			总砷			<0.0003		mg/L			
			总铅			<0.07	0.1	mg/L	是		
			总镍			<0.02	0.5	mg/L	是		
			氨氮			0.17	15	mg/L	是		
			石油类			<0.04	2.0	mg/L	是		
			悬浮物			<4	30	mg/L	是		
			总氮			3.12	20	mg/L	是		
			总磷			0.04	1.0	mg/L	是		
			化学需氧量			13	80	mg/L	是		
总银	<0.03	0.1	mg/L	是							
总氰化物	0.001	0.2	mg/L	是							
pH值	7.40	6~9	无量纲	是							
总铝	<0.07	2.0	mg/L	是							
总铁	<0.02	2.0	mg/L	是							
氟化物	0.20	10	mg/L	是							
总铜	<0.006	0.5	mg/L	是							
含镍废水						总汞	<0.00004	0.01	mg/L	是	
						总镉	<0.001	0.05	mg/L	是	
						总铬	<0.03	1.0	mg/L	是	

23	东莞 辖镇	富加宜连 连接器（东 莞）有限 公司	预处理排 放口	电镀水污 染物排放 标准	2017/7/11	六价铬	<0.004	0.2	mg/L	是	
			含铅废水 预处理排 放口			总铅	<0.01	0.2	mg/L	是	
						总镍	<0.05	0.5	mg/L	是	
			排放口			总银	<0.03	0.3	mg/L	是	
						总汞	0.000057	0.01	mg/L	是	
						总镉	<0.001	0.05	mg/L	是	
						总铬	<0.03	1.0	mg/L	是	
						六价铬	<0.004	0.2	mg/L	是	
						总铅	<0.01	0.2	mg/L	是	
						总镍	<0.05	0.5	mg/L	是	
						总银	<0.03	0.3	mg/L	是	
						总铅	<0.01	0.1	mg/L	是	
						总镍	<0.05	0.1	mg/L	是	
						总铜	<0.05	0.3	mg/L	是	
						总锌	<0.02	1	mg/L	是	
						总汞	<0.00004	0.005	mg/L	是	
						总镉	<0.001	0.01	mg/L	是	
						总铬	<0.03	0.5	mg/L	是	
						氨氮	0.060	8	mg/L	是	
						氟化物	0.50	10	mg/L	是	
						石油类	<0.04	2.0	mg/L	是	
						悬浮物	<4	30	mg/L	是	
						总氮	7.52	15	mg/L	是	
			总磷			0.16	0.5	mg/L	是		
			化学需氧量			19	50	mg/L	是		
			总铁			0.06	2.0	mg/L	是		
			总银			<0.03	0.1	mg/L	是		
			总氰化物			0.002	0.2	mg/L	是		
			pH 值			7.34	6~9	无量纲	是		
			总铝			1.77	2.0	mg/L	是		
			六价铬			<0.004	0.1	mg/L	是		
			总砷			<0.0003		mg/L			

注：<表示检验数值低于方法最低检出限，以所使用的方法检出限值报出。